



NOTES:

1. PROVIDE 6" MINIMUM STONE DEPTH
2. USE #5 WASHED STONE AND RAILROAD BALLAST MIX
3. INSTALL SOIL STABILIZATION FABRIC OR 4" COMPACTED ABC STONE UNDER ENTRANCE
4. ANY AGGREGATE TRACKED INTO THE ROADWAY MUST BE SWEEPED BACK ONSITE ON A NIGHTLY BASIS
5. MINIMUM LENGTH OF ENTRANCE = 25'

NOT TO SCALE



CITY OF CHARLOTTE
 LAND DEVELOPMENT STANDARDS
 INCLUDES CHARLOTTE ETJ

CONSTRUCTION ENTRANCE
 SINGLE FAMILY LOT

STD. NO.	REV.
30.11C	12