



Charlotte Department of Transportation

Memorandum

Date: March 4, 2008

To: Tammie Keplinger & Tom Drake
Charlotte-Mecklenburg Planning Department

From: 
Scott L. Putnam
Development Services Division

Subject: Rezoning Petition 08-055: Located on the east side of East W.T. Harris Boulevard between Old Concord Road and Back Creek Drive

Consistency with Transportation Action Plan (TAP): The two goals of the TAP that most directly affected the staff's review of this petition define the integration of land use and transportation, and the provision of transportation choices.

- Goal 1 of the TAP relies on the Centers, Corridors and Wedges land use strategy to be implemented. This project site is located in a Corridor and appears to support the Centers, Corridors and Wedges land use strategy as increased activity in a Corridor.
- Goal 2 of the TAP describes various connectivity and design features that are important for motorists, pedestrians and bicyclists. Specific comments are identified below that need to be addressed for CDOT's support of the petition and to bring the site plan into compliance with the TAP and best practices for multimodal transportation.

Vehicle Trip Generation

This site could generate approximately 100 peak trips as currently zoned. Under the proposed zoning the site could generate approximately 125 peak trips. This will have a minor impact on the surrounding thoroughfare system.

We have the following specific comments that are critical to CDOT's support of the rezoning petition:

1. The site must use existing access points. No additional access onto WT Harris Boulevard will be permitted.

We have the following specific comments that are important to CDOT's support of the rezoning petition. We would like the petitioner to give serious consideration to these comments/requests. These may require coordination with related CMPC issues.

1. The pedestrian path that exists along the frontage adjacent to the site to the north should be continued across this property frontage.

We have the following general comments that are provided to aid the petitioner in planning and subsequent permitting phases:

Adequate sight triangles must be reserved at the existing/proposed street entrance(s). Two 35' x 35' and two 10' x 70' sight triangles are required for the entrance(s) to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs must not interfere with sight distance at the entrance(s). Such items should be identified on the site plan.

Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.

A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to the construction/installation of the non-standard item(s). Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements.

To facilitate building permit/driveway permit review and approval, the site plan must be revised to include the following:

- All City of Charlotte Land Development Standards (latest revision) will apply.
- Indicate the locations and widths of all adjacent and opposing driveways.
- Indicate typical parking module dimensions.
- Directional wheelchair ramps (two per corner) should be provided at all intersections of public and private streets.

If we can be of further assistance, please advise.

SLP

c: R. H. Grochoske (via email)
S. L. Habina – Review Engineer (via email)
B. D. Horton (via email)
A. Christenbury (via email)
E. D. McDonald (via email)
Merrifield Partners, LLC/Edwin Thomas (via email)
Kennedy Covington/Laura Simmons (via email)
NCDOT/Scott Cole (via email)
NCDOT/Louis Mitchell (via email)
Rezoning File