



# Charlotte Department of Transportation

## Memorandum

---

**Date:** July 29, 2008

**To:** Tom Drake & Tammie Keplinger  
Charlotte-Mecklenburg Planning Department

**From:**   
Scott L. Putnam  
Development Services Division

**Subject:** Rezoning Petition 08-128: Located on the west side of Statesville Road  
between Twin Lakes Parkway and Future I-485

---

**Consistency with Transportation Action Plan (TAP):** The two goals of the TAP that most directly affected the staff's review of this petition define the integration of land use and transportation, and the provision of transportation choices.

- Goal 1 of the TAP relies on the Centers, Corridors and Wedges land use strategy to be implemented. This project site is located in a Corridor and appears to support the Centers, Corridors and Wedges land use strategy.
- Goal 2 of the TAP describes various connectivity and design features that are important for motorists, pedestrians and bicyclists. Specific comments are identified below that need to be addressed for CDOT's support of the petition and to bring the site plan into compliance with the TAP and best practices for multimodal transportation.

### Vehicle Trip Generation

This site could generate approximately 800 trips per day as currently zoned. Under the proposed zoning the site could generate approximately 700 trips per day. This will have a lesser and minor impact on the surrounding thoroughfare system.

We have the following specific comments that are critical to CDOT's support of the rezoning petition:

1. The developer needs to construct 5-foot sidewalks and 8-foot planting strips along the newly created dead-end street following the former alignment of Statesville Road.
2. A turnaround in the public right-of-way in the form of a cul-de-sac needs to be provided at the end of the existing old alignment of Statesville Road as shown on the site plan. If this has not been completed by the North Carolina Department of Transportation, it will be required as a condition of this rezoning petition. The access to the site will be a driveway off this permanently dead-ended street.

3. The developer needs to construct a 10-foot width multi-use path running a minimum of 25-feet outside the right-of-way of and parallel to the new alignment of Statesville Road.

We have the following specific comments that are important to CDOT's support of the rezoning petition. We would like the petitioner to give serious consideration to these comments/requests. These may require coordination with related CMPC issues.

1. The developer needs to construct 5-foot minimum internal sidewalks connecting all primary entrances with requested sidewalk along the newly created dead-end street following the former alignment of Statesville Road.

We have the following general comments that are provided to aid the petitioner in planning and subsequent permitting phases:

Adequate sight triangles must be reserved at the existing/proposed street entrance(s). Two 35' x 35' and two 10' x 70' sight triangles are required for the entrance(s) to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs must not interfere with sight distance at the entrance(s). Such items should be identified on the site plan.

The proposed driveway connection(s) to existing Statesville Road will require a driveway permit(s) to be submitted to CDOT and the North Carolina Department of Transportation for review and approval. The exact driveway location(s) and type/width of the driveway(s) will be determined by CDOT during the driveway permit process. The locations of the driveway(s) shown on the site plan are subject to change in order to align with driveway(s) on the opposite side of the street and comply with City Driveway Regulations and the City Tree Ordinance.

Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.

A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to the construction/installation of the non-standard item(s). Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements.

To facilitate building permit/driveway permit review and approval, the site plan must be revised to include the following:

- Meet applicable Land Development Standards (latest revision).
- Dimension width of the existing and proposed driveways.

Tom Drake & Tammie Keplinger

July 29, 2008

Page 3 of 3

- New/reconstructed driveways must be drop curb Type II-Modified driveways.
- Indicate the locations and widths of all adjacent and opposing driveways.
- Indicate typical parking module dimensions.
- Include a parking summary with figures for the numbers of parking spaces required and provided.
- Directional wheelchair ramps (two per corner) should be provided at all intersections of public and private streets.

If we can be of further assistance, please advise.

SLP

c: R. H. Grochoske (via email)  
S. L. Habina – Review Engineer (via email)  
B. D. Horton (via email)  
A. Christenbury (via email)  
E. D. McDonald (via email)  
Sherpa Land Company/ Stuart Mullen (via email)  
NCDOT/Louis Mitchell (via email)  
NCDOT/Scott Cole (via email)  
Rezoning File