



- NOTES:
1. CONTRACTOR TO FURNISH "T" - HANDLE VALVE KEY AND WRENCH FOR 2" NUT AS PERMANENT STATION EQUIPMENT.
  2. PUMP CONNECTIONS LARGER THAN 8" SHALL BE HOUSED IN VAULT SIZED AS REQUIRED FOR APPLICATION AS DETERMINED BY CMU.
  3. ALL VALVES OPEN LEFT.

**CHARLOTTE-MECKLENBURG UTILITIES**  
SYSTEM PROTECTION DIVISION  
CHARLOTTE, NORTH CAROLINA

STANDARD DETAIL  
SEWER PUMP STATION

EMERGENCY PUMP  
CONNECTION DETAIL  
UP TO 8-INCH

Job No. _____	File No. _____	Surveyed By _____		Designed By _____		Drawn By _____		EAB _____		Approved By _____		Date	4/2003	Sheet	2
PLAN _____	Scale _____	As Built _____		Date _____		B.I.W. _____		EAB _____		Approved By _____		Date	4/2003	Sheet	2
PROFILE _____	N.T.S.	Date _____		Date _____		Date _____		Date _____		Date _____		Date	4/2003	Sheet	2
Hor. _____		Date _____		Date _____		Date _____		Date _____		Date _____		Date	4/2003	Sheet	2
Vert. _____		Date _____		Date _____		Date _____		Date _____		Date _____		Date	4/2003	Sheet	2