



NOTES:

1. ACTUAL SITE CONDITIONS MAY REQUIRE ADDITIONAL LIMITS OF CONSTRUCTION TO BE DETERMINED BY THE CITY (MINIMUM SHOWN).
2. SEE APPROPRIATE CURB DETAIL FOR CURB INSTALLATION.
3. CONCRETE SHALL BE A MINIMUM OF 3600 PSI.
4. ASPHALT TYPE (*) TO MATCH SPECIFIED STREET DETAIL STANDARD PAVEMENT STRUCTURE OR AS DIRECTED BY CITY ENGINEER (SEE STREET TYPICAL DETAIL STANDARD).
5. RESURFACING LIMITS ON NCDOT-MAINTAINED ROADS TO BE DETERMINED BY NCDOT.

NOT TO SCALE



CITY OF CHARLOTTE
LAND DEVELOPMENT STANDARDS
INCLUDES CHARLOTTE ETJ

CURB REPAIRS AT EXISITING BUS STOPS

STD. NO.	REV.
10.38	23