

PLAN REVIEW SHEET

Date: 7/23/2024

Petition #: 2024-075

plan review process.

Staff Contact: Evan Punch

The Site is located at 7852 Arboretum Dr and is served by CATS bus route #51. CATS requires the upgrade of an existing bus stop to an ADA-compliant bus standard detail 60.01A along Pineville-Matthews Rd. The final location will be coordinated with the developer during the Land Development

LEGEND BOARDING AND ALIGHTING AREA BUS SIGN SIDEWALK MUST MATCH CONCRETE 4" THICK SLOPE OF BOARDING AND ALIGHTING AREA TRASH RECEPTACLE RIGHT OF WAY 5' WIDE SIDEWALK NOTES THICK STANDARDS, VARIATIONS MUST BE APPROVED THROUGH CATS AND CDOT PROJECT MANAGER. PLANTING STRIP 2' MIN. WIDTH, VARIES 2. WIDTH OF EXISTING SIDEWALK PLUS PLANTING STRIP WIDTH MUST EQUAL 8' WIDE. IF WIDTH IS LESS THAN 8', EXISTING SIDEWALK MUST BE REPLACED WITH WIDER SIDEWALK TO OBTAIN 8' WIDTH. GUTTER STREET PLAN VIEW SEE SHEET NO. 60.07A, 60.07B, AND 60.07C FOR ADDITIONAL DETAILS AND NOTES. NO. DATE DESCRIPTION APPROVED DATE BUS STOP WITH PLANTING VI S STRIP, MINIMUM WIDTH STD. NO. REV. 60.01A