



MECKLENBURG COUNTY
Land Use & Environmental Services Agency

MEMORANDUM

To: Charlotte-Mecklenburg Planning Commission
From: LUESA, Mecklenburg County
Date: 10.24.24
Subject: Rezoning Petition Comments

Charlotte-Mecklenburg Planning Commission
600 East Fourth Street Charlotte, North Carolina 28202

Mecklenburg County has reviewed the City of Charlotte rezoning petition below to identify regulatory requirements of the petitioner; inform the petitioner, planning staff, and other affected parties of such regulatory requirements; and identify potential effects on, and impacts from, nearby properties.

<u>Petitioner Information:</u> Mary Dominick 7210 Benita Dr Charlotte, NC, 28212-7005 Home Phone: 7042803193 Mobile Phone: 7042803193 mcdomino@live.com	<u>Parcel GIS ID(s):</u> 18909128
--	---

2024-109: Burtonwood Neighborhood RIO

Air Quality Comments: No Comments

Ground Water Services Comments: *Executive Summary: Septic system registration records were noted for several parcels in the petition. Additionally, site may contain an underground or above ground storage tank.*

Groundwater & Wastewater Services records indicate a registered septic system exists on parcels listed in the petition. No regulations govern the abandonment of septic systems; however, GWS does recommend that septic tanks be pumped by a NC Licensed Septic Hauler to remove any residual contents and then

crushed and backfilled. This recommendation is made because improperly abandoned septic tanks may not be able to support the weight of vehicular traffic, structural foundations or people posing a safety hazard.

Information from property records indicate that the building(s) on the site uses or previously utilized oil, wood or coal heat. Based on this the property may contain an underground or above ground fuel oil storage tank. The tank and its contents should be removed, following applicable NCDEQ guidance, prior to any demolition or grading activity.

Storm Water Services Comments: No Comments

Solid Waste Comments: No Comments

Department Contacts:

Petitioners seeking to address individual comments and issues may follow up with the following Mecklenburg County staff:

Air Quality Comments: Megan Green - (megan.green@mecklenburgcountync.gov)

Ground Water Services: Shawna Caldwell - (shawna.caldwell@mecklenburgcountync.gov)

Storm Water Services: Myrette Stephen - (myrette.stephen@mecklenburgcountync.gov)

Solid Waste Comments: Joe Hack - (joe.hack@mecklenburgcountync.gov)

Additionally, please CC Erin Stanforth, (erin.stanforth@mecklenburgcountync.gov) on all communications to individual departments.

MCAQ Scope of Review:

Mecklenburg County Air Quality (MCAQ) has reviewed the petitions with regard to air quality regulations for stationary sources and demolition and/or renovation of structures (e.g. National Emission Standards for Hazardous Air Pollutants for asbestos). Comments may also be made regarding incompatible land uses, sources of Toxic Air Pollutants, proximity to Risk Management Plan facilities, and proximity to known nuisance conditions or sensitive populations. MCAQ has conducted the review based on information submitted by the petitioner, review of aerial photographs (as available through the Mecklenburg County Polaris system), review of the "Air Pollution Facility Information Online" database available from the MCAQ website, and review of Mecklenburg County Health Department records. The review is cursory based on limited information provided within petition applications and site plans.