



NO.	DESCRIPTION:
1.	FIRE HYDRANT.
2.	KUPFERLE #9700-Y HYDRANT AUTO FLUSHER (YELLOW) (INCLUDING #8-19).
3.	6 MILS HDPE PLASTIC FILM (54" X 54") - SEE NOTE C.
4.	16" X 16" X 2" PATIO PAVERS - CONCRETE - 8 EA - SEE NOTE C.
5.	HYDRANT STORZ NOZZLE W/RED OUT-OF-SERVICE RING (O.D. = 12.5", I.D. = 7.0", t = 0.05").
6.	CAMPBELL BLU-KROME 1/4" PROOF COIL CHAIN 5 LF.
7.	LOCKING NOZZLE COLLAR - KUPFERLE #9708-Y WITH PADLOCK.
8.	2 1/2" FIRE HYDRANT NOZZLE COUPLING.
9.	KUPFERLE ADAPTER.
10.	2" THREADED NIPPLE.
11.	2" X 2" X 2" TEE FIP THREAD.
12.	PLUG/TAP.
13.	WATER SAMPLE VALVE.
14.	BRASS WATER SAMPLING BIBB.
15.	2" SOLENOID CONTROL VALVE; P-220 SERIES.
16.	MANUAL FLOW CONTROL KNOB.
17.	HUNTER DIGITAL PROGRAMMABLE CONTROLLER WITH 9 VOLT LITHIUM BATTERY.
18.	2" FIP OUTLET (MAY BE HARD PIPED FOR DISCHARGE).
19.	REMOVABLE DIFFUSER PLATE WITH 4 BOLTS/NUTS.
20.	PADLOCK (PROVIDED BY CLTW).

NOTES:

A. AUTO FLUSHER IS INTENDED FOR WARM WEATHER USE. ASSEMBLY SHOULD BE REMOVED DURING COLD WEATHER MONTHS TO AVOID DAMAGE DUE TO FREEZING.

B. MANUAL FLUSHING REQUIRED TO MAINTAIN WATER QUALITY DURING COLD WEATHER MONTHS.

C. SHOWN AS TEMPORARY APPLICATION - IF PERMANENT INSTALLATION - REPLACE NO. 3 AND NO. 4 WITH CAST IN PLACE CONCRETE PAD - MIN. 4' X 4' X 4" THICK WITH WIRE REINFORCEMENT, FLUSH WITH FINISH GRADE.