



- NO. DESCRIPTION:
1. 24" CAST IRON MANHOLE FRAME AND COVER (EQUIPMENT ACCESS) PER CLTW STANDARDS - TYPE C / 1 CENTER OVER AIR / VACUUM VALVE.
  2. STAINLESS STEEL PIPE SUPPORT WITH SADDLE.
  3. PROTECTO 401 LINED DIP FORCE MAIN. MIN 40 FT EACH SIDE OF VAULT.
  4. GREEN PLASTIC WARNING TAPE.
  5. ROAD SIDE DITCH UNDISTURBED SOIL.
  6. PVC PIPE ON EITHER SIDE OF VAULT, UNLESS CALLED OUT OTHERWISE.
  7. PRECAST CONCRETE OR POLYMER CONCRETE VAULT. SEE COMBINATION AIR AND VACUUM VALVE FOR SEWER FORCE MAINS DETAIL.
  8. #57 WASHED STONE.
  9. PRECAST CONCRETE BASE SECTION.
  10. 6" RJ DIP - MIN. 0.50% POSITIVE SLOPE.
  11. BREAK AWAY FLANGE CONNECTION WITH SS BREAK AWAY BOLTS.
  12. FL JOINT.
  13. RJ FLEXIBLE CONNECTION SLEEVE.
  14. 18" DIAMETER AUGER HOLE/CONCRETE FOOTING.
  15. 5" OR 6" STEEL VENT PIPE - SEE STD DETAIL.
  16. ROAD ROW OR CLTW EASEMENT.