



## *2018 Annual Drinking Water Quality Report* *Charlotte Water*

Water System Number: 01-60-010

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a snapshot of last year's water quality. Included are details about your source(s) of water, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your drinking water. **If you have any questions about this report or concerning your water, please call 311 or 704-336-7600. We want our valued customers to be informed about their water utility.**

### **What EPA Wants You to Know**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Charlotte Water is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which

can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; and radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

## **When You Turn on Your Tap, Consider the Source**

Mountain Island Lake and Lake Norman supply our treatment plants with high quality water for your home, business or school. These surface waters are part of the Catawba River Basin, which provides water for more than 1.5 million people in our growing region. Charlotte Water operates three water treatment plants, and they collectively treat an average of 107 million gallons of water a day.

### **Our Treatment Process**

Long before you step in the shower or turn on the tap, Charlotte Water employees have managed numerous processes to protect our drinking water and those who use it. First we pump the water from Mountain Island Lake and Lake Norman to one of the three water treatment plants - Franklin, Vest or Dukes. We add powdered activated carbon for taste and odor control followed by aluminum sulfate (alum) in the rapid mix phase to cause dirt particles to coagulate, which are then removed through settling. The water then flows through filters that trap even smaller particles. We add chlorine to prevent bacterial growth and fluoride to promote dental health. We also add lime to adjust the water's pH, which helps prevent pipe corrosion and the leaching of metals into the water. We then pump the water to homes, businesses and storage tanks through over 4,300 miles of water pipes.

## **Source Water Assessment Program (SWAP) Results**

The North Carolina Department of Environmental Quality (DEQ) Public Water Supply (PWS) Section, Source Water Assessment Program (SWAP) conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source (well or surface water intake) to Potential Contaminant Sources (PCSs). The results of the assessment are available in SWAP Assessment Reports that include maps, background information and a relative susceptibility rating of Higher, Moderate or Lower.

The relative susceptibility rating of each source for Charlotte Water was determined by combining the contaminant rating (number and location of PCSs within the assessment area) and the inherent vulnerability rating (i.e., characteristics or existing conditions of the well or watershed and its delineated assessment area). The assessment findings are summarized in the table below:

## Susceptibility of Sources to Potential Contaminant Sources (PCSs)

Source	Inherent Vulnerability Rating	Contaminant Rating	Susceptibility Rating	Date
Mt. Island Lake/Catawba River	Moderate	Moderate	Moderate	September 2017
Lake Norman	Higher	Higher	Higher	September 2017

The complete SWAP Assessment report for Charlotte Water may be viewed on the Web at: [www.ncwater.org/pws/swap](http://www.ncwater.org/pws/swap). Note that because SWAP results and reports are periodically updated by the PWS Section, the results available on this web site may differ from the results that were available at the time this Consumer Confidence Report (CCR) was prepared. If you are unable to access your SWAP report on the web, you may mail a written request for a printed copy to: Source Water Assessment Program – Report Request, 1634 Mail Service Center, Raleigh, NC 27699-1634, or email requests to [swap@ncdenr.gov](mailto:swap@ncdenr.gov). Please indicate your system name, number, and provide your name, mailing address and phone number. If you have any questions about the SWAP report please contact the Source Water Assessment staff by phone at 919-707-9098.

It is important to understand that a susceptibility rating of “higher” does not imply poor water quality, only the system’s potential to become contaminated by PCSs in the assessment area.

### Help Protect Your Source Water

Protection of drinking water is everyone’s responsibility. Charlotte Water is partnering with Charlotte-Mecklenburg Storm Water Services to expand the scope of source water quality sampling in Lake Norman and Mountain Island Lake. Multiple locations from both source waters are now being monitored. You can help protect your community’s drinking water source(s) in several ways: If you see or suspect potential water contaminations, water leaks, or sewage spills, please call 311 or 704-336-7600. We will respond 24 hours-a-day, 365 days-a-year. Dispose of chemicals properly and take used motor oil to the four Mecklenburg County recycling centers.

Put only toilet paper in the toilet. All other products should go in the trash including ‘flushable’ wipes.

### Water Quality Data Tables of Detected Contaminants

We routinely monitor for over 150 contaminants in your drinking water according to Federal and State laws. The tables below list all the drinking water contaminants that we detected in the last round of sampling for each particular contaminant group. The presence of contaminants does not necessarily indicate that water poses a health risk. **Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, (2018).** The EPA and the State allow us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

## **Important Drinking Water Definitions:**

***Not-Applicable (N/A)*** – Information not applicable/not required for that particular water system or for that rule.

***Non-Detects (ND)*** - Laboratory analysis indicates that the contaminant is not present at the level of detection set for the particular methodology used.

***Parts per million (ppm) or Milligrams per liter (mg/L)*** - One part per million corresponds to one minute in two years or a single penny in \$10,000.

***Parts per billion (ppb) or Micrograms per liter (ug/L)*** - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

***Parts per trillion (ppt) or Nanograms per liter (nanograms/L)*** - One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

***Parts per quadrillion (ppq) or Picograms per liter (picograms/L)*** - One part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

***Picocuries per liter (pCi/L)*** - Picocuries per liter is a measure of the radioactivity in water.

***Million Fibers per Liter (MFL)*** - Million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

***Nephelometric Turbidity Unit (NTU)*** - Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

***Action Level (AL)*** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

***Treatment Technique (TT)*** - A required process intended to reduce the level of a contaminant in drinking water.

***Maximum Residual Disinfection Level (MRDL)*** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

***Maximum Residual Disinfection Level Goal (MRDLG)*** - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

***Locational Running Annual Average (LRAA)*** - The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters under the Stage 2 Disinfectants and Disinfection Byproducts Rule.

**RAA**- Running annual average

***Maximum Contaminant Level (MCL)*** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

***Maximum Contaminant Level Goal (MCLG)*** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

***Total Organic Carbon (TOC)*** - has no health effects, however, organics provide a medium for the formation of disinfection byproducts. The TOC compliance criterion applies only to treated water.

## Tables of Detected Contaminants

### Microbiological Contaminants in the Distribution System

Contaminant (units)	MCL Violation Y/N	Your Water	MCLG	MCL	Likely Source of Contamination
E. coli (presence or absence) Distribution System	No	0	0	Routine and repeat samples are total coliform-positive and either is E. coli-positive or system fails to take repeat samples following E. coli-positive routine sample or system fails to analyze total coliform-positive repeat sample for E. coli  <u>Note:</u> If either an original routine sample and/or its repeat samples(s) are E. coli positive, a Tier 1 violation exists.	Human and animal fecal waste

E.coli - Fecal coliforms and E.coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely-compromised immune systems.

### Turbidity\*

Contaminant (units)	Year Sampled	Treatment Technique (TT) Violation Y/N	Your Water	MCLG	Treatment Technique (TT) Violation if:	Likely Source of Contamination
Turbidity (NTU) - Highest single turbidity measurement  Franklin Vest Dukes	2018	No	0.10 0.09 0.10	N/A	Turbidity > 1 NTU	Soil runoff
Turbidity (NTU) - Lowest monthly percentage (%) of samples meeting turbidity limits  Franklin Vest Dukes	2018	No	100% 100% 100%	N/A	Less than 95% of monthly turbidity measurements are ≤ 0.3 NTU	

\*Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. The turbidity rule requires that 95% or more of the monthly samples must be less than or equal to 0.3 NTU.

## Inorganic Contaminants

Contaminant	Year Sampled	MCL Violation Y/N	Your Water (average)	Range Low-High	MCLG	Likely source of contamination
Fluoride (ppm) Franklin Vest* Dukes	2018		0.67 0.69 0.70	0.57-0.85 0.13-0.79 0.54-0.81	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories

\*Fluoride system upgrades account for low readings

## Lead and Copper Contaminants

Contaminant (units)	Year Sampled	Your Water	Number of sites found above the AL	MCLG	AL	Likely Source of Contamination
Copper (ppm) (90 <sup>th</sup> percentile)	2016	None detected at 90 <sup>th</sup> percentile	0	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb) (90 <sup>th</sup> percentile)	2016	None detected at 90 <sup>th</sup> percentile	1	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits

## Total Organic Carbon (TOC)

Contaminant (units)	Year Sampled	TT Violation Y/N	Your Water (RAA Removal Ratio)	Range Monthly Removal Ratio Low - High	MCLG	TT	Likely Source of Contamination	Compliance Method (Step 1 or ACC#_)
Total Organic Carbon (removal ratio) (TOC)-TREATED (ppm) Franklin Vest Dukes	2018	No	1.22 1.01 0.98	0.99-1.35 0.71-1.20 0.71-1.27	Compliance Method ACC#2 Treated Water <2.00 ppm	TT	Naturally present in the environment	ACC#2

## Disinfectant Residuals Summary

	Year Sampled	MRDL Violation Y/N	Your Water (highest RAA)	Range		MRDLG	MRDL	Likely Source of Contamination
				Low	High			
Chlorine (ppm) Franklin Vest Dukes Distribution System	2018	No	1.33 1.32 1.33 1.16	1.00 - 1.68 1.06 - 1.66 1.03 - 1.70 0.42 - 1.65		4	4.0	Water additive used to control microbes

## Other Disinfection Byproducts Contaminants

Contaminant (units)	Year Sampled	MCL/MRDL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
*Chlorite (ppm) Dukes Distribution System	2016	No	0.100 0.014	0.063 - 0.137 ND - 0.048		0.8	1.0	By-product of drinking water chlorination

\*Charlotte Water conducted a commissioning study for the startup of a chlorine dioxide generation system at Lee Dukes plant over a 2 day period in April 2016 (4/5 & 4/6). The application of chlorine dioxide as a pre-oxidant enhances water quality by reducing disinfection byproducts (DBP), and also functions as an oxidizing agent to counter soluble manganese and iron concentrations in untreated, raw water along with providing bacteriological inactivation. The purpose of the commissioning study was to generate chlorine dioxide, apply the chlorine dioxide in the water treatment process, and evaluate performance. Chlorine Dioxide was not fed at any time during 2018; therefore, chlorite was not required to be monitored.

## Stage 2 Disinfection Byproduct Compliance - Based upon Locational Running Annual Average (highest LRAA)

Disinfection Byproduct	Year Sampled	MCL Violation Y/N	Your Water (highest LRAA)	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
TTHM (ppb)	2018	No	56.3	19.0 - 88.2		N/A	80	Byproduct of drinking water disinfection
HAA5 (ppb)	2018	No	20.6	11.4 - 26.4		N/A	60	Byproduct of drinking water disinfection

For TTHM: Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

For HAA5: Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

## Other Miscellaneous Water Characteristics Contaminants

Contaminant (units)	Sample Date	Your Water	Range		Secondary MCL
			Low	High	
Alkalinity (ppm)	2018	16	13	17	N/A
Aluminum (ppb)	2018	40	27	78	50-200 ppb
Calcium Hardness as CaCO <sub>3</sub> (ppm)	2018	19	7	23	N/A
Chloride (ppm)	2018	7.1	4.5	8.4	250 ppm
Conductivity (umhos/cm)	2018	81	78	84	N/A
Hardness, Total as CaCO <sub>3</sub> (ppm)	2018	24	14	27	N/A
Magnesium (ppm)	2018	2	1.7	2.2	N/A
Silica (ppm)	2018	9.6	8.2	11	N/A
Sodium (ppm)	2018	4	3	5	N/A
Sulfate (ppm)	2018	8.3	3.4	9.2	250 ppm
Total Dissolved Solids (TDS) (ppm)	2018	59	39	74	500 ppm

\*The PWS Section requires monitoring for other misc. contaminants, some for which the EPA has set national secondary drinking water standards (SMCLs) because they may cause cosmetic effects or aesthetic effects (such as taste, odor, and/or color) in drinking water. The contaminants with SMCLs normally do not have any health effects and normally do not affect the safety of your water.

## Unregulated Contaminants Monitoring - UCMR 4

Contaminant (units)	Year Sampled	Your Water (Highest)	Range	
			Low	High
Bromide (Raw Water) (ppb)	2018	40.8	23.2	40.8
TOC, Raw Water (ppm)	2018	1.87	1.62	1.87
Manganese, Entry Point to DS (ppb)	2018	121.0	0.59	121.0
Bromochloroacetic acid, DS (ppb)	2018	4.06	2.53	4.93
Bromodichloroacetic acid, DS (ppb)	2018	2.33	1.42	3.31
Chlorodibromoacetic acid, DS, (ppb)	2018	0.68	0.35	1.34

\*Unregulated Contaminants monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.