


NOTES

1. TEMPORARY TURNAROUND MATERIAL SHALL BE MIN. 3600 PSI CONCRETE, 6" THICK.
2. TEMPORARY INSTALLATION ONLY – TO BE REMOVED WHEN FUTURE DEVELOPMENT CONNECTS TO STREET. "SIDEWALK" PORTION OF TURNAROUND MAY BE LEFT IN PLACE IF NOT DAMAGED.
3. NOT TO BE USED AS A PRIVATE DRIVEWAY.
4. DEAD END STREET BARRICADE AND END OF ROADWAY MARKER PER CLDSM #50.07A&B AND #50.08A, B, & C ARE REQUIRED.

SCALE 1"=10'



CITY OF CHARLOTTE
LAND DEVELOPMENT STANDARDS
 INCLUDES CHARLOTTE ETJ

TEMPORARY TURNAROUND
 LOCAL RESIDENTIAL STREET
 (OPTIONAL)

STD. NO.	REV.
11.18B	13