



NOTES:

1. NOT TO SCALE.
2. APPLICATION DESIGNED FOR TREES NO LESS THAN 12" IN DIAMETER.
3. FILL – SEE CLDSM – PLANTING MIX. APPLY TO A DEPTH OF FOUR (4) INCHES AT BASE OF TREE, TAPER TO GRADE. SEED AND MULCH ACCORDING TO CLDSM.
4. STONE – #5, WASHED. MAINTAIN EXPOSED SIX (6) INCH WIDTH AT TRUNK OF TREE. PLACE TO MINIMUM DEPTH OF TWELVE (12) INCHES AND A MAXIMUM OF TWENTY-FOUR (24) INCHES AT THE BASE OF THE TREE AND TAPER OUTWARD TO NO LESS THAN TEN (10) FEET.
5. FABRIC – NON-WOVEN GEOTEXTILE FABRIC, SUCH AS MIRAFI OR EQUIVALENT, PLACED BETWEEN STONE AND FILL. IT IS NOT TO COVER STONE EXPOSED AT TRUNK OF TREE.



CITY OF CHARLOTTE
 LAND DEVELOPMENT STANDARDS
 INCLUDES CHARLOTTE ETJ

ROCK CHIMNEY

STD. NO.	REV.
40.14	