



NOTES:

1. THIS DETAIL IS TO BE USED ONLY WITH PRIOR APPROVAL BY CDOT AND CHARLOTTE FIRE DEPARTMENT.
2. ADJACENT CURB RAMPS SHALL BE INSTALLED PER CLDSM 10.31, MODIFIED TO A 1 1/4" DEPRESSION AT BACK OF CURB.
3. PROVIDE APPROPRIATE STORM DRAINAGE MEASURES TO ENSURE WATER DOES NOT POND AT ANY POINT ALONG THE SURFACE CROSSWALK OR AT THE BASE OF THE RAISED CROSSWALK.
4. THE CROSSWALK SURFACE RUNNING SLOPE AND CROSS SLOPE SHALL NOT EXCEED THAT OF THE EXISTING ROADWAY.
5. STORM GRATES SHALL NOT BE INSTALLED INTO THE TAPERS OR TABLE PORTION OF THE RAISED CROSSWALK.
6. THIS DETAIL IS NOT PERMITTED FOR USE ON NCDOT-MAINTAINED ROADWAYS.

NOT TO SCALE

