

2018-034 1-For non-sprinkled buildings. Fire department must be able to reach 150' to all exterior portion of building. 2- For sprinkled buildings. Fire department must be able to reach 200' to all exterior portion of building. 3-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for a NFPA 13 sprinkler system and 750' for a NFPA 13R sprinkler system. 4- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings.

2019-089 1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. 3- Turn radius 30' inside and 42' outside. 4- For non-sprinkled buildings. Fire department must be able to reach 150' to all exterior portion of building. 5- For sprinkled buildings. Fire department must be able to reach 200' to all exterior portion of building. 6- For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for a NFPA 13 sprinkler system and 750' for a NFPA 13R sprinkler system. 7- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings.

2019-128 1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. 3- Turn radius 30' inside and 42' outside. 4- For non-sprinkled buildings. Fire department must be able to reach 150' to all exterior portion of building. 5- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings.

2019-163 1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. 3- Turn radius 30' inside and 42' outside. 4- For non-sprinkled buildings. Fire department must be able to reach 150' to all exterior portion of building. 5- For sprinkled buildings. Fire department must be able to reach 200' to all exterior portion of building. 6- For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for a NFPA 13 sprinkler system. 7- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings.

2019-180 1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Turn radius 30' inside and 42' outside. 3- For non-sprinkled buildings. Fire department must be able to reach 150' to all exterior portion of building. 4- For sprinkled buildings. Fire department must be able to reach 200' to all exterior portion of building. 5- For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for a NFPA 13 sprinkler system. 6- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings.

