

2018-034        1- For non-sprinkled buildings. Fire department must be able to reach 150' to all exterior portion of building. 2- For sprinkled buildings. Fire department must be able to reach 200' to all exterior portion of building. 3- For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for a NFPA 13 sprinkler system and 750' for a NFPA 13R sprinkler system. 4- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings.

2019-115        Same comment.

2019-156        No comments.

2019-160        Same comments.

2019-167        Same comments.

2019-168        Same comments.

2019-173        Same comment.

2019-184        Same comments.