

Rezoning Transportation Analysis

Petition Number: 2019-179

General Location Identifier: 08119159

From: Felix Obregon, PE
fobregon@charlottenc.gov
704-432-5729

Reviewer: Walta Blackmon, PE
walta.brumschine@ci.charlotte.nc.us
704-432-1556

Revision Log:

Date	Description
01-15-2020	First Review
02-17-2020	Second Review
04-23-2020	Third Review

General Review Information

The site is on Parkwood Avenue (major thoroughfare, city maintained) and is in a wedge inside Route 4.

Active Projects Near the Site:

- Parkwood (N. Davidson -The Plaza) Improvements
 - This project will install pavement markings to create a buffered bike lane on Parkwood Avenue from Belmont Avenue to The Plaza. Several new signals will be added with the project limits as well.

CDOT's review of this rezoning petition is intended to provide consistency with council adopted policies, plans, standards and guidelines including, but not limited to, the [Transportation Action Plan \(TAP\)](#), [Vision Zero](#), [Urban Street Design Guidelines \(USDG\)](#), [Center, Corridor and Wedges](#), [Charlotte BIKES](#), [Traffic Impact Study Guidelines](#) and [Charlotte WALKS](#). With a commitment to design complete streets, this review is to ensure that the City's transportation network supports current and future land uses and includes streets that provide safe and comfortable mobility for motorists, pedestrians, bicyclists, and transit users.

This document is primarily for communication to Planning Department staff as part of the overall City staff analysis of the rezoning petition and includes an overall summary of the case from a transportation perspective, information on trip generation, and resolved or outstanding site plan concerns. Additional advisory information about the driveway permit process is provided for information only.

Based on our review of the petition, we offer the following information for your consideration.

Transportation Summary

The site is located on a major thoroughfare road. CDOT is requesting the petitioner construct a Multi-Use Path to create better connectivity between Mimosa Avenue and the Proposed Site until such time where a road can be constructed in the future. CDOT is also requesting the petitioner update the site plan to construct a public road to USDG standards as dictated by the subdivision ordinance. The petitioner should revise the site plan to meet the ordinance requirements and the outstanding items listed below.

Trip Generation

Scenario	Land Use	Intensity	Trip Generation (vehicle trips/day)	Source
Existing Use	Vacant	NA	0	Tax Record
Entitlement with	Single Family	5 dwellings	50	General Guidance

Rezoning Transportation Analysis

Petition Number: 2019-179

General Location Identifier: 08119159

Current Zoning	(1 ac of R-5)			from Planning
Proposed Zoning	Single Family Apartments	8 dwellings 12 dwellings	140	Site Plan: 12-10-20

Please provide responses to our comments as part of your resubmittal.

Outstanding Issues

Strikeout = Not an outstanding issue

1. ~~**Curbline** The proposed zoning district has a setback measured from back of the existing future curbline.~~
 - a. ~~**Parkwood Ave:** The future location of curb and gutter is in its existing location.~~

The site plan should show the curb and gutter labeled and dimensioned from the centerline for each road.
2. ~~**Traffic Study** A Traffic Impact Study is not necessary for the complete review of this petition.~~

If during the permitting process the site generates more than 2500 daily trips, then a traffic study will be required.
3. ~~The petitioner should revise the site plan and conditional note(s) to create a Multi-Use Path from Mimosa Avenue to connect into proposed site.~~
4. The petitioner should revise the site plan and conditional note(s) to construct private drive to a public USDG standard. This a requirement of the Subdivision ordinance. If the proposed access meets the required ordinance, please provide the documentation stating it meets the ordinance.
5. ~~The petitioner should revise the site plan to add a note specifying dedication and fee simple conveyance of all rights of way to the City before the site's first building certificate of occupancy is issued. CDOT requests right of way set at 2' behind back of sidewalk where feasible.~~
6. ~~The petitioner should revise the site plan to add a note specifying all transportation improvements will be approved and constructed before the site's first building certificate of occupancy is issued. The petitioner may phase transportation improvements if said improvements and phasing are explicitly described in site plan notes.~~
7. ~~The site plan and conditional note(s) should be updated to show all deliveries for multi-family buildings will occur onsite.~~
8. ~~New Comment based on site plan 02/10/2020: Petitioner should update the conditional notes to remove conditional note 9 under Transportation. In the future, CDOT may decide to extend the road in the future and may need portions of this property in order to facilitate this.~~
9. **New Comment based on site plan 04/14/2020:** Petitioner should revise the driveway to Mimosa Avenue to meet Charlotte Land Development Standards Manual for two-way circulation since it is a shared driveway.
10. ~~**Resolved** Sample format for comment that is resolved~~

Advisory Information

The following are requirements of the developer that must be satisfied prior to driveway permit approval. We recommend that the petitioner reflect these on the rezoning plan as-appropriate.

Rezoning Transportation Analysis

Petition Number: 2019-179

General Location Identifier: 08119159

1. The setback for this district is measured from the back of the existing or future curbline as determined by CDOT and Planning during the permitting process.
2. According to the City of Charlotte's Driveway Regulations, CDOT has the authority to regulate/approve all private street/driveway and public street connections to the right-of-way of a street under the regulatory jurisdiction of the City of Charlotte.
3. Adequate sight triangles must be reserved at the existing/proposed street entrance(s). Two 35' x 35' sight triangles (and two 10' x 70' sight triangles on North Carolina Department of Transportation on NCDOT maintained streets) are required for the entrance(s) to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs must not interfere with sight distance at the entrance(s). Such items should be identified on the site plan.
4. The proposed driveway connection(s) to public streets will require a driveway permit(s) to be submitted to CDOT (and the North Carolina Department of Transportation on NCDOT maintained streets) for review and approval. The exact driveway location(s) and type/width of the driveway(s) will be determined by CDOT during the driveway permit process. The locations of the driveway(s) shown on the site plan are subject to change in order to align with driveway(s) on the opposite side of the street and comply with City Driveway Regulations and the City Tree Ordinance.
5. All proposed commercial driveway connections to a future public street will require a driveway permit to be submitted to CDOT for review and approval.
6. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.
7. A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to the construction/installation of the non-standard item(s). Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements.