

2019-128        1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-Turn radius 30' inside and 42' outside. 4- Access road that exceeds 150' shall provide an approved turnaround. 5-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for a 13 type sprinkler system and 750' for a 13R type sprinkler system. 6- Dead end access road that exceeds 150' shall provide an approved turnaround.

2019-163        Same comments.

2019-179        1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. This requirement hasn't been met. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. This requirement hasn't been met. 3- Turn radius 30' inside and 42' outside. 4- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings.

2019-184        Same comments.