

Acela Number	
2019-170	<b>1- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 2- For non-sprinkled buildings. Fire department must be able to reach all</b>
2019-171	<b>No Comments. Rezoning request.</b>
2019-172	<b>No Comments. Rezoning request.</b>
2019-173	<b>No Comments. Rezoning request.</b>
2019-174	<b>1- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 2- For non-sprinkled buildings. Fire department must be able to reach all exterior portion of building within 150' from access road. 3- For sprinkled buildings. Fire department must be able to reach all exterior portion of building within 200' from access road. 4- For buildings that is equipped with a sprinkler system. A fire department connection shall be</b>
2019-175	<b>1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-Turn radius 30' inside and 42' outside. 4-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for</b>
2019-176	<b>No comments. Rezoning request.</b>

<b>2019-177</b>	<b>capable of supporting 80,000 lbs. 2- Turn radius 30' inside and 42' outside. 3- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings.</b>
<b>2019-178</b>	<b>1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. 3- Turn radius 30' inside and 42' outside. 4- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 5- For</b>
<b>2019-179</b>	<b>1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. 3- Fire hydrant shall be located within 750' to the most remote point o</b>
<b>2019-180</b>	<b>1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. 3- Turn radius 30' inside and 42' outside. 4- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 5- For non-sprinkled buildings. Fire department must be able to reach all exterior portion of building within 150' from access road. 6- For sprinkled buildings. Fire department must be able to reach</b>
<b>2019-181</b>	<b>1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3- For sprinkled buildings. Fire department must be able to reach all exterior portion of building within 200' from access road. 4- For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for a NFPA 13 sprinkler system and 750' for a NFPA 13R sprinkler system.</b>

<b>2019-182</b>	<b>No comments. Rezoning request.</b>
<b>2019-183</b>	<b>No comments.</b>
<b>2019-184</b>	<b>1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Turn radius 30' inside and 42' outside. 3- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 4- For sprinkled buildings. Fire department must be able to reach all exterior portion of building within 200' from access road. 5- For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for a NFPA 13 sprinkler</b>
<b>2019-185</b>	<b>No comments.</b>