

Acela Number	
2019-170	1- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 2- For non-sprinkled buildings. Fire department must be able to reach all
2019-171	No Comments. Rezoning request.
2019-172	No Comments. Rezoning request.
2019-173	No Comments. Rezoning request.
2019-174	1- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 2- For non-sprinkled buildings. Fire department must be able to reach all exterior portion of building within 150' from access road. 3- For sprinkled buildings. Fire department must be able to reach all exterior portion of building within 200' from access road. 4- For buildings that is equipped with a sprinkler system. A fire department connection shall be
2019-175	1-Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3-Turn radius 30' inside and 42' outside. 4-For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for
2019-176	No comments. Rezoning request.

2019-177	capable of supporting 80,000 lbs. 2- Turn radius 30' inside and 42' outside. 3- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings.
2019-178	1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. 3- Turn radius 30' inside and 42' outside. 4- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 5- For
2019-179	1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. 3- Fire hydrant shall be located within 750' to the most remote point o
2019-180	1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire department access road that exceeds 150' shall provide an approved turnaround. 3- Turn radius 30' inside and 42' outside. 4- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 5- For non-sprinkled buildings. Fire department must be able to reach all exterior portion of building within 150' from access road. 6- For sprinkled buildings. Fire department must be able to reach
2019-181	1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 3- For sprinkled buildings. Fire department must be able to reach all exterior portion of building within 200' from access road. 4- For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for a NFPA 13 sprinkler system and 750' for a NFPA 13R sprinkler system.

2019-182	No comments. Rezoning request.
2019-183	No comments.
2019-184	1- Fire department access road shall have a min. 20' unobstructed clear width and shall be capable of supporting 80,000 lbs. 2- Turn radius 30' inside and 42' outside. 3- Fire hydrant shall be located within 750' to the most remote point of building as truck travel for all buildings. 4- For sprinkled buildings. Fire department must be able to reach all exterior portion of building within 200' from access road. 5- For buildings that is equipped with a sprinkler system. A fire department connection shall be located within 200' of a fire hydrant for a NFPA 13 sprinkler
2019-185	No comments.