



PLAN REVIEW SHEET

Date: October 22, 2020

Petition #: RZP 2020-134

Request: CC

Staff Contact: John Howard

The site is located along CATS local bus route #18 along Mount Holly Road. CATS requests the petitioner to construct an ADA compliant bus waiting pad per Land Development Standard 60.01B at the location of the existing stop (ID #46533). The final location of the pad will be coordinated with the developer through the permitting process.

