

Rezoning Transportation Analysis

Petition Number: 2020-026

General Location Identifier: Tax ID04940106

From: Felix Obregon, PE
fobregon@charlottenc.gov
704-432-5729

Reviewer: Walta Brumskine
Walta.brumskine@ci.charlotte.nc.us
704-432-1556

Revision Log:

Date	Description
03-25-2020	First Review

General Review Information

The project is located on Shopping Center Drive (local, private) and Hampton Church Road (local, city maintained) and is within 250 feet of N Tryon Street (major thoroughfare, State maintained).

It is located outside of Route 4.

The site is within the limits of the University City Area Plan and University City-McCullough Transit Station Area Plans.

Active Projects Near the Site:

- N. Tryon Street (US 29/NC 49)
 - The project will implement the widening of N. Tryon Street to include a 6 Lane Divided (Median or Center Turn Lane) with Bike Facilities and Sidewalks

CDOT's review of this rezoning petition is intended to ensure consistency with the Transportation Action Plan (TAP) which seeks to ensure that the City's transportation network supports current and future land uses and includes streets that provide safe and comfortable mobility for motorists, pedestrians, bicyclists, and transit users.

This document is primarily for communication to Planning Department staff as part of the overall City staff analysis of the rezoning petition and includes an overall summary of the case from a transportation perspective, information on trip generation, and resolved or outstanding site plan concerns. Additional advisory information about the driveway permit process is provided for information only.

Based on our review of the petition, we offer the following information for your consideration.

Transportation Summary

The site is located on a local road. The petitioner should revise the site plan to meet the ordinance requirements and the outstanding items listed below.

Trip Generation

Scenario	Land Use	Intensity	Trip Generation (vehicle trips/day)	Source
Existing Use	Vacant	-	-	-
Entitlement with Current Zoning	B-1(CD)	75,300 SF Retail	4,960	General Guidance from Planning
Proposed Zoning	Apartments	140 DU	765	Site Plan: 01-24-20
Proposed Zoning	Apartments	200 DU	1090	Site Plan: 04-13-20

Outstanding Issues

~~Strikeout~~ = Not an outstanding issue

Rezoning Transportation Analysis

Petition Number: 2020-026

General Location Identifier: Tax ID04940106


- ~~1. **Curbline** The proposed zoning district has a setback measured from back of the existing or proposed future curbline.
 - ~~a. **Hampton Church Road Name:** The future location of curb and gutter is in its existing location.~~
 - ~~b. **Shopping Center Drive:** The future location of curb and gutter is in its existing location.~~~~

~~The site plan should show the curb and gutter labeled and dimensioned from the centerline for each road.~~

- ~~2. **Traffic Study** A Traffic Impact Study is not necessary for the complete review of this petition. If during the permitting process the site generates more than 2500 daily trips, then a traffic study will be required.~~

~~Staff will receive the petition and begin work on it, but the public hearing will not be scheduled until the TIS is received. This will allow for the minimum time necessary for CDOT to review and approve the study and reach agreement with the petitioner on the required transportation commitments, and have them included on the last site plan submitted no fewer than 4 weeks prior to the public hearing. Therefore, additional traffic mitigation comments may be forthcoming once the TIS is approved by CDOT and NCDOT.~~

- ~~3. The proposed dwelling units per acre exceeds 12. Per Chapter 20 Subdivision ordinance, the petitioner should revise the site plan and conditional note(s) to commit to construct an 8-foot planting strip, and 8-foot sidewalk along Public Street A.~~
- ~~4. The petitioner should revise the site plan and conditional note(s) to commit to providing two ADA curb ramps to provide pedestrian or bike crossing Shopping Center Drive.~~




- ~~5. The petitioner should revise the site plan and conditional note(s) to align the proposed street and driveways across the street to provide a safer access. (Revised on 04-17-220)~~

Rezoning Transportation Analysis

Petition Number: 2020-026

General Location Identifier: Tax ID04940106



6. The petitioner should revise the site plan to add a note specifying dedication and fee simple conveyance of all rights of way to the City before the site's first building certificate of occupancy is issued. CDOT requests right of way set at 2' behind back of sidewalk where feasible.
7. The petitioner should revise the site plan to add a note specifying all transportation improvements will be approved and constructed before the site's first building certificate of occupancy is issued. The petitioner may phase transportation improvements if said improvements and phasing are explicitly described in site plan notes.
8. **Resolved**-Sample format for comment that is resolved

Advisory Information

The following are requirements of the developer that must be satisfied prior to driveway permit approval. We recommend that the petitioner reflect these on the rezoning plan as-appropriate.

1. The setback for this district is measured from the back of the existing or future curbline as determined by CDOT and Planning during the permitting process.
2. According to the City of Charlotte's Driveway Regulations, CDOT has the authority to regulate/approve all private street/driveway and public street connections to the right-of-way of a street under the regulatory jurisdiction of the City of Charlotte.
3. Adequate sight triangles must be reserved at the existing/proposed street entrance(s). Two 35' x 35' sight triangles (and two 10' x 70' sight triangles on North Carolina Department of Transportation on NCDOT maintained streets) are required for the entrance(s) to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs must not interfere with sight distance at the entrance(s). Such items should be identified on the site plan.
4. The proposed driveway connection(s) to public streets will require a driveway permit(s) to be submitted to CDOT (and the North Carolina Department of Transportation on NCDOT maintained streets) for review and approval. The exact driveway location(s) and type/width of the driveway(s) will be determined by CDOT during the driveway permit process. The locations of the driveway(s) shown on the site plan are subject to change in order to align with driveway(s) on the opposite side of the street and comply with City Driveway Regulations and the City Tree Ordinance.
5. All proposed commercial driveway connections to a future public street will require a driveway permit to be submitted to CDOT for review and approval.

Rezoning Transportation Analysis

Petition Number: 2020-026

General Location Identifier: Tax ID04940106

6. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.
7. A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to the construction/installation of the non-standard item(s). Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements.