

Rezoning Transportation Analysis

Petition Number: 2020-038

General Location Identifier: Tax ID 20143102

From: Felix Obregon, PE
fobregon@charlottenc.gov
704-432-5729

Reviewer: Eric Lemieux, PE
eric.lemieux@charlottenc.gov
704-336-2683

Revision Log:

Date	Description
04-22-2020	First Review

General Review Information

The site is located on Steele Creek Road (state maintained, major thoroughfare) in wedge outside of Route 4. The site is located within the Steele Creek Area Plan.

Active Projects Near the Site:

- Steele Creek Rd. Widening (NC 160) – I-485 to South Carolina line
 - Project scope: Widen existing NC 160 to a 4-lane superstreet with multi-use paths (6 lanes in some areas)
 - ROW Year 2021
 - Construction Year 2024
 - PM: NCDOT
 - TIP #: U-5766

CDOT's review of this rezoning petition is intended to provide consistency with council adopted policies, plans, standards and guidelines including, but not limited to, the [Transportation Action Plan \(TAP\)](#), [Vision Zero](#), [Urban Street Design Guidelines \(USDG\)](#), [Center, Corridor and Wedges](#), [Charlotte BIKES](#), [Traffic Impact Study Guidelines](#) and [Charlotte WALKS](#). With a commitment to design complete streets, this review is to ensure that the City's transportation network supports current and future land uses and includes streets that provide safe and comfortable mobility for motorists, pedestrians, bicyclists, and transit users.

This document is primarily for communication to Planning Department staff as part of the overall City staff analysis of the rezoning petition and includes an overall summary of the case from a transportation perspective, information on trip generation, and resolved or outstanding site plan concerns. Additional advisory information about the driveway permit process is provided for information only.

Based on our review of the petition, we offer the following information for your consideration.

Transportation Summary

The site is located on a major thoroughfare road. The petitioner should revise the site plan to meet the ordinance requirements and the outstanding items listed below.

Trip Generation

Scenario	Land Use	Intensity	Trip Generation (vehicle trips/day)	Source
Existing Use	Single Family	1 DU	9	Tax Record
Entitlement with	Single Family (R-3,	29 DU	335	General Guidance

Rezoning Transportation Analysis

Petition Number: 2020-038

General Location Identifier: Tax ID 20143102

Current Zoning	9.96 acres)			from Planning
Proposed Zoning	Apartments	119 DU	650	Site Plan: 02-14-20

Please provided responses to our comments.

Outstanding Issues

~~Strikeout~~ = Not an outstanding issue

1. **Curblin**e The proposed zoning district has a setback measured from back of the existing or proposed future curblin)e.
 - a. **Steele Creek Road:** Location of curb and gutter needs to be shown on the plans based on the NCDOT TIP Project (U-5766) NC 160. The curb and gutter doesn't need to be constructed, but it does need to be shown on the plans.

The site plan should show the curb and gutter labeled and dimensioned from the centerline for each road.
2. **Traffic Study** A Traffic Impact Study is not necessary for the complete review of this petition due to the site generation more than 2500 daily trips. If the during the permitting process the site generates more than 2500 daily trips, then a traffic study will be required.
3. The petitioner should revise the site plan and conditional note(s) to commit to dedicate right-of-way from the road centerline for the NCDOT TIP Project (U-5766) NC 160. You can contact NCDOT for the exact location of the curb and gutter. The site plan should label and dimension the right-of-way from the road centerline.
4. The petitioner should revise the site plan and conditional note(s) to commit to a 100' right-turn lane into the NC 160 access point. It is an NCDOT requirement.
5. The petitioner should revise the site plan and conditional note(s) to commit to provide a 50-foot driveway stem from the future NC 160 right-of-way line.
6. The petitioner should revise the site plan and conditional note(s) to commit to construct a left-turn lane with 150' of storage and appropriate left-turn lane tapers based on the speed limit.
7. The petitioner should revise the site plan and conditional note(s) to show an exhibit showing full access with left-turn lane, and the future access on NC 160, based on the NCDOT NC 160 widening project. A conditional note should be added that the access will be changed based on the NCDOT project.
8. The petitioner should revise the site plan and conditional note(s) to commit to construct an 8-foot planting strip, and 6-foot sidewalk on Cedar Crossing Drive to meet the Subdivision ordinance. The site plan should label and dimension both items from the back of curb and gutter and road centerline.
9. The petitioner should revise the site plan and conditional note(s) to commit to construct an 8-foot planting strip, and 12-foot multi-use path on Steele Creek Road at its ultimate location. The site plan should label and dimension both items from the back of curb and gutter and road centerline
10. The petitioner should revise the site plan and conditional note(s) to include an additional access point to Cedar Crossing Drive, as the Subdivision ordinance require two access points for this type of development. The access should be located opposite of Kendrick Crossing Road.

Rezoning Transportation Analysis

Petition Number: 2020-038

General Location Identifier: Tax ID 20143102

11. The petitioner should revise the site plan and conditional note(s) to include a sidewalk connection from the site to the sidewalk along Cedar Crossing Drive.
12. The petitioner should revise the site plan to add a note specifying dedication and fee simple conveyance of all rights of way to the City before the site's first building certificate of occupancy is issued. CDOT requests right of way set at 2' behind back of sidewalk where feasible.
13. The petitioner should revise the site plan to add a note specifying all transportation improvements will be approved and constructed before the site's first building certificate of occupancy is issued. The petitioner may phase transportation improvements if said improvements and phasing are explicitly described in site plan notes.
14. ~~Resolved-Sample format for comment that is resolved~~

Advisory Information

The following are requirements of the developer that must be satisfied prior to driveway permit approval. We recommend that the petitioner reflect these on the rezoning plan as-appropriate.

1. According to the City of Charlotte's Driveway Regulations, CDOT has the authority to regulate/approve all private street/driveway and public street connections to the right-of-way of a street under the regulatory jurisdiction of the City of Charlotte.
2. Adequate sight triangles must be reserved at the existing/proposed street entrance(s). Two 35' x 35' sight triangles (and two 10' x 70' sight triangles on North Carolina Department of Transportation on NCDOT maintained streets) are required for the entrance(s) to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs must not interfere with sight distance at the entrance(s). Such items should be identified on the site plan.
3. The proposed driveway connection(s) to public streets will require a driveway permit(s) to be submitted to CDOT (and the North Carolina Department of Transportation on NCDOT maintained streets) for review and approval. The exact driveway location(s) and type/width of the driveway(s) will be determined by CDOT during the driveway permit process. The locations of the driveway(s) shown on the site plan are subject to change in order to align with driveway(s) on the opposite side of the street and comply with City Driveway Regulations and the City Tree Ordinance.
4. All proposed commercial driveway connections to a future public street will require a driveway permit to be submitted to CDOT for review and approval.
5. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.
6. A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to the construction/installation of the non-standard item(s). Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements.