

Rezoning Transportation Analysis

Petition Number: 2020-039

General Location Identifier: Tax ID 12709221

From: Felix Obregon, PE
fobregon@charlottenc.gov
704-432-5729

Reviewer:Walta Blackmon, PE
walta.brumschine@ci.charlotte.nc.us
704-432-1556

Revision Log:

Date	Description
04-22-20	First Review
05-20-2020	Second Review

General Review Information

The site is located on 7th Street (state maintained, major thoroughfare), and Firefighter Place (City maintained, local road) in a wedge within Route 4.

Active Projects Near the Site:

- Briar Creek Greenway, Central Ave. to Monroe Rd. (proposed access across Firefighter Pl. from site)
 - Scope: construct new greenway between Central Ave. and Monroe Rd./7th St.
 - Current phase: Design
 - PM: Mecklenburg County Park & Rec

CDOT's review of this rezoning petition is intended to provide consistency with council adopted policies, plans, standards and guidelines including, but not limited to, the [Transportation Action Plan \(TAP\)](#), [Vision Zero](#), [Urban Street Design Guidelines \(USDG\)](#), [Center, Corridor and Wedges](#), [Charlotte BIKES](#), [Traffic Impact Study Guidelines](#) and [Charlotte WALKS](#). With a commitment to design complete streets, this review is to ensure that the City's transportation network supports current and future land uses and includes streets that provide safe and comfortable mobility for motorists, pedestrians, bicyclists, and transit users.

This document is primarily for communication to Planning Department staff as part of the overall City staff analysis of the rezoning petition and includes an overall summary of the case from a transportation perspective, information on trip generation, and resolved or outstanding site plan concerns. Additional advisory information about the driveway permit process is provided for information only.

Based on our review of the petition, we offer the following information for your consideration.

Transportation Summary

The site is located on a major thoroughfare road. The site plan commits to an 8-foot planting strip and 8-foot sidewalk along 7th Street and Fireplace Place. CDOT continues to request the construction of the accessible ramps and associated pedestrian signal improvements to meet Charlotte WALKS City policy and accessible ramp requirements to promote walkability to the nearby Briar Creek Greenway.

Trip Generation

Scenario	Land Use	Intensity	Trip Generation (vehicle trips/day)	Source
Existing Use	Vacant	-	-	-

Rezoning Transportation Analysis

Petition Number: 2020-039

General Location Identifier: Tax ID 12709221

Entitlement with Current Zoning	Apartments (R-22MF, .44 acres)	9 DU	50	General Guidance from Planning
Proposed Zoning	Townhomes	10 DU	75	Site Plan: 05-11-20

Please provide responses to our comments.


Outstanding Issues

Strikeout = Not an outstanding issue

- Curbline** ~~The proposed zoning district has a setback measured from back of the existing or proposed future curblin.~~
 - ~~**Monroe Road:** The future location of curb and gutter is in its existing location.~~
 - ~~**Firefighter Place:** The future location of curb and gutter is in its existing location.~~

~~The site plan should show the curb and gutter labeled and dimensioned from the centerline for each road.~~

- Traffic Study** ~~A Traffic Impact Study is not necessary for the complete review of this petition due to the site generation more than 2500 daily trips. If during the permitting process the site generates more than 2500 daily trips, then a traffic study will be required.~~
- ~~The petitioner should revise the site plan and conditional note(s) to commit to dedicate 40' of right-of-way from the road centerline, as it is a major thoroughfare and within Route 4. The site plan should label and dimension the right of way from the road centerline.~~
- The petitioner should revise the site plan and conditional note(s) to commit to construct dual ramps at the corner of E 7th Street and E. 5th Street to meet the City's Charlotte WAKS Policy and PROWAG. In addition, the developer should commit to provide accessible push buttons for its corner. The site plan should label and dimension both items from the back of curb and gutter and road centerline.




- We request for the petitioner should revise the site plan and conditional note(s) to commit to construct dual ramps at the corner of Monroe Road and E. 5th Street to meet City's Charlotte WAKS Policy and PROWAG. The site plan should label and dimension both items from the back of curb and gutter and road centerline.

Rezoning Transportation Analysis

Petition Number: 2020-039

General Location Identifier: Tax ID 12709221



6. The petitioner should revise the site plan to add a note specifying dedication and fee simple conveyance of all rights of way to the City before the site's first building certificate of occupancy is issued. CDOT requests right of way set at 2' behind back of sidewalk where feasible.
7. The petitioner should revise the site plan to add a note specifying all transportation improvements will be approved and constructed before the site's first building certificate of occupancy is issued. The petitioner may phase transportation improvements if said improvements and phasing are explicitly described in site plan notes.
8. ~~Resolved~~ ~~Sample format for comment that is resolved~~

Advisory Information

The following are requirements of the developer that must be satisfied prior to driveway permit approval. We recommend that the petitioner reflect these on the rezoning plan as-appropriate.

1. The setback for this district is measured from the back of the existing or future curbline as determined by CDOT and Planning during the permitting process.
2. According to the City of Charlotte's Driveway Regulations, CDOT has the authority to regulate/approve all private street/driveway and public street connections to the right-of-way of a street under the regulatory jurisdiction of the City of Charlotte.
3. Adequate sight triangles must be reserved at the existing/proposed street entrance(s). Two 35' x 35' sight triangles (and two 10' x 70' sight triangles on North Carolina Department of Transportation on NCDOT maintained streets) are required for the entrance(s) to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs must not interfere with sight distance at the entrance(s). Such items should be identified on the site plan.
4. The proposed driveway connection(s) to public streets will require a driveway permit(s) to be submitted to CDOT (and the North Carolina Department of Transportation on NCDOT maintained streets) for review and approval. The exact driveway location(s) and type/width of the driveway(s) will be determined by CDOT during the driveway permit process. The locations of the driveway(s) shown on the site plan are subject to change in order to align with driveway(s) on the opposite side of the street and comply with City Driveway Regulations and the City Tree Ordinance.
5. All proposed commercial driveway connections to a future public street will require a driveway permit to be submitted to CDOT for review and approval.
6. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.
7. A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to the construction/installation of the non-standard item(s). Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements.