



**MECKLENBURG COUNTY**  
Land Use and Environmental Services Agency

**From:** Dylan Kirk, Mecklenburg County LUESA  
**Date:** Wednesday, May 27, 2020  
**Subject:** City of Charlotte April Initial Rezoning Petitions

Charlotte-Mecklenburg Planning Commission  
600 East Fourth Street Charlotte, North Carolina 28202

Mecklenburg County has reviewed the City of Charlotte rezoning petition below to identify regulatory requirements of the petitioner; inform the petitioner, planning staff, and other affected parties of such regulatory requirements; and identify potential effects on, and impacts from, nearby properties.

GIS ID
04545110
04545103

**2020-062: KSS Charlotte**

*Air Quality Comments:* No comment on this rezoning petition.

*Ground Water Services Comments:* GWS records indicate a contamination site(s) exist on or within 1,500 feet of the properties included in the petitions. An established Area of Regulated Groundwater Usage (ARGU) as defined by the Mecklenburg County Groundwater Well Regulations extends 1,500 feet around the contamination sites. In ARGU where municipally supplied water is available water supply wells for water supply, irrigation or open loop geothermal systems may not be permitted or constructed on or within 1,000 feet of contamination sites. Wells may be permitted with special construction and sampling requirements between 1,000 and 1,500 feet of contamination sites. Where no other water sources are available, wells may be permitted with special construction and sampling requirements within 1,500' of contamination sites.

*Storm Water Services Comments:* No comments from Permitting & Compliance, Storm Water Service and Water Quality.

*Solid Waste Comments:* No comments.

**Department Contacts:**

Petitioners seeking to address individual comments / issues may follow up with the following individual Mecklenburg County staff:

*Air Quality Comments:* PJ McKenzie - (paul.mckenzie@mecklenburgcountync.gov)  
*Ground Water Services:* Shawna Caldwell - (shawna.caldwell@mecklenburgcountync.gov)  
*Storm Water Services:* Myrette Stephen - (myrette.stephen@mecklenburgcountync.gov)  
*Solid Waste Comments:* Joe Hack - (joe.hack@mecklenburgcountync.gov)

Please CC Dylan Kirk, (dylan.kirk@mecklenburgcountync.gov) on all communications to individual departments, thank you.

**MCAQ Scope of Review:**

MCAQ has reviewed the petitions with regard to air quality regulations for stationary sources and demolition and/or renovation of structures (e.g. National Emission Standards for Hazardous Air Pollutants for asbestos). Comments may also be made regarding incompatible land uses, sources of Toxic Air Pollutants, proximity to Risk Management Plan facilities, and proximity to known nuisance conditions or sensitive populations. MCAQ has conducted the review based on information submitted by the petitioner, review of aerial photographs (as available through the Mecklenburg County Polaris system,) review of the “Air Pollution Facility Information Online” database available from the MCAQ website, and review of Mecklenburg County Health Department records. The review is cursory based on limited information provided within petition applications and site plans.