



Charlotte Storm Water
600 East Fourth Street
Charlotte, N C 28202-2844

Rezoning Petition Review

To: Charlotte Planning, Design & Development

From: Doug Lozner

Date of Review: August 27, 2020

Rezoning Petition #: 20-94

Existing Zoning: R-22MF and I-1 (CD)

Proposed Zoning: I-1 (CD) and I-1 (CD) SPA

Location of Property: Approximately 9.54 acres located along the north side of Perimeter Pointe Pkwy and Glen Lake Dr, south of West Blvd and east of Billy Graham Pkwy

Site Plan Submitted: Yes

Recommendations Concerning Storm Water: Flooding and surface water quality impacts associated with impervious surfaces on this site are being addressed through compliance with the Post-Construction Stormwater Ordinance. Compliance may include installing devices that hold and slowly release runoff over time to reduce flooding potential, devices that filter pollutants from runoff before release to streams, preservation of vegetated stream buffer zones, preservation of upland trees and forested areas, or paying a mitigation fee in-lieu-of onsite stormwater control devices. Compliance with the Post-Construction Stormwater Ordinance addresses concerns related to flooding and surface water impacts and therefore staff has no further comments.