PLAN REVIEW SHEET

Date: April 29, 2021

Petition #: RZP 2021-039

Address: 9327 Legranger Road

Request: RE-3 (O)

Staff Contact: John Howard

The site is located along a future CATS local bus route. CATS requests the construction of an ADA compliant bus pad per Land Development Standard 60.01B on Senator Royall Drive. The final location of the pads will be coordinated with the developer through the permitting process.



PLAN VIEW
NTS

LEGEND

TRASH RECEPTACLE

SIGN

ADA SPACE

NEW CONCRETE WAITING PAD 4" THICK

NOTES:

1. DIMENSIONS REPRESENT MINIMUM STANDARDS; VARIATIONS MUST BE APPROVED THROUGH CATS AND CDOT PROJECT MANAGER.
2. SEE SHEETS NO. 07A AND 07B FOR ADDITIONAL DETAILS AND NOTES.
3. WIDTH OF SIDEWALK PLUS PLANTING STRIP MUST EQUAL 8'. IF WIDTH IS LESS THAN 8', EXISTING SIDEWALK MUST BE REPLACED WITH WIDER SIDEWALK TO OBTAIN 8'.

APPROVED DATE _____

CHARLOTTE AREA TRANSIT SYSTEM

WAITING PAD ONLY WITH PLANTING STRIP STANDARD

STD. NO.	REV.
60.01B	1