PLAN REVIEW SHEET

Date: May 27, 2021

Petition #: RZP 2021-061

Address: 4700 Prosperity Church Road

Request: UR-2 CD

Staff Contact: John Howard

The site is located along CATS local bus route #59 along Prosperity Church Road. CATS requests the construction of an ADA compliant bus pad per Land Development Standard 60.01B on Prosperity Church Road. The final location of the pads will be coordinated with the developer through the permitting process.



PLAN VIEW
NTS

LEGEND

TRASH RECEPTACLE

SIGN

ADA SPACE

NEW CONCRETE WAITING PAD 4" THICK

NOTES:

1. DIMENSIONS REPRESENT MINIMUM STANDARDS; VARIATIONS MUST BE APPROVED THROUGH CATS AND CDOT PROJECT MANAGER.
2. SEE SHEETS NO. 07A AND 07B FOR ADDITIONAL DETAILS AND NOTES.
3. WIDTH OF SIDEWALK PLUS PLANTING STRIP MUST EQUAL 8'. IF WIDTH IS LESS THAN 8', EXISTING SIDEWALK MUST BE REPLACED WITH WIDER SIDEWALK TO OBTAIN 8'.

APPROVED DATE _____

CHARLOTTE AREA TRANSIT SYSTEM

WAITING PAD ONLY WITH PLANTING STRIP STANDARD

STD. NO.	REV.
60.01B	1