

# Rezoning Transportation Analysis

Petition Number: Zoning Petition #2021-011

General Location Identifier: Tax ID 10304127

**From: Robyn Byers, Ph.D.**  
Robyn.Byers@ci.charlotte.nc.us  
704-336-7404

**Reviewer:** Walta Blackmon, PE  
Walta.Brumskine@charlottenc.gov  
704-432-1556

## Revision Log:

Date	Description
02-25-21	First Review (WB)
03-25-21	Second Review (WB)
04-27-21	Third Review (WB)

## General Review Information

The petition is located adjacent to Central Avenue (City-maintained, Major Thoroughfare) near Sharon Amity Road (City-maintained, Major Thoroughfare). The petition is in the Eastland Center and is inside Route 4. Applicable area plans include the Eastland Area Plan.

## Active Projects Near the Site:

- None

---

*CDOT's review of this rezoning petition is intended to provide consistency with council adopted policies, plans, standards and guidelines including, but not limited to, the Transportation Action Plan (TAP), Vision Zero, Urban Street Design Guidelines (USDG), Center, Corridor and Wedges, Charlotte BIKES, Traffic Impact Study Guidelines and Charlotte WALKS. With a commitment to design complete streets, this review is to ensure that the City's transportation network supports current and future land uses and includes streets that provide safe and comfortable mobility for motorists, pedestrians, bicyclists, and transit users.*

---

*This document is primarily for communication to Planning Department staff as part of the overall City staff analysis of the rezoning petition and includes an overall summary of the case from a transportation perspective, information on trip generation, and resolved or outstanding site plan concerns. Additional advisory information about the driveway permit process is provided for information only.*

---

Based on our review of the petition, we offer the following information for your consideration.

## Transportation Summary

The site is located on a City-maintained major thoroughfare (Central Avenue), within the study limits of the Eastland Mall TIS and the CATS Streetcar Project. A Traffic Impact Study is no longer required for this site due to the change in land use and the reduction in intensity as proposed in the revised site plan dated March 15, 2021. The CDOT-approved Eastland Mall TIS conducted capacity analysis and recommended improvements to intersections, signals and multi-modal transportation infrastructure, enhancing vehicular, bicycle and pedestrian connectivity in this area. This petitioner will need to coordinate with the Eastland Mall and the CATS Streetcar Projects to ensure continuity of pedestrian and bicycle facilities within the site's vicinity. All outstanding CDOT comments have been addressed.

## Trip Generation

Scenario	Land Use	Intensity	Trip Generation (vehicle trips/day)	Source
Existing Use	Charter School			Tax Record
Entitlement with	Charter School	98,000 SF	1,750	RZ 2019-055

# Rezoning Transportation Analysis

Petition Number: Zoning Petition #2021-011

General Location Identifier: Tax ID 10304127

Current Zoning	EDEE	2,000 SF		
Proposed Zoning	Drive-Thru restaurant	6,000 SF	2,830	Site Plan: 12-07-20
Proposed Zoning	Charter School	98,000 SF	2,630	Site Plan: 03-15-21
	EDEE	2,000 SF		
	Retail	6,000 SF		

Provide comments to the specified comments below.

## Outstanding Issues

**Strikethrough = Resolved**

- Curbline:** The proposed zoning district has a setback measured from back of the existing or proposed future curbline.

**Central Avenue:** Location of curb and gutter needs to be at 38 feet from the centerline to allow for a 4+ Avenue with an 8-foot buffered bike lane. **Rescinded (3/22/2021) based on meeting held on March 15<sup>th</sup>. The future curb and gutter will be located 38 feet from the centerline; however, CDOT will not require the relocation of the existing curb and gutter for this site plan, in order to tie into the CATS Street Car project and maintain a continuous typical section along Central Avenue.**

~~Label and dimension the existing curb and gutter from the road centerline on the site plan.~~

- ~~**Traffic Study:**~~

~~A Traffic Impact Study (TIS) is not necessary for the complete review of this petition due to the site generating less than 2,500 daily trips. If during the permitting process the site generates more than 2,500 daily trips, then a traffic study will be required.~~

- ~~Revise site plan and conditional note(s) to commit to construct an 8-foot planting strip, and 8-foot sidewalk on Central Avenue per Chapter 19. The wider sidewalk also meets the Charlotte WALKS Policy. The site plan shall label and dimension both items from the back of curb and gutter. **Rescinded (3/22/2021)**~~
- ~~Site plan and conditional note(s) revisions are needed to commit to construct 8' buffered bicycle lanes by relocating the curb and gutter 38' from the center line to meet the City Charlotte BIKE Policy. **Rescinded (3/22/2021)**~~
- ~~Revise or Remove Conditional Note B.1, based on the results of the Traffic Impact Study, which may not allow vehicular circulation or maneuvering to occur in the setback area between Central Avenue and the buildings. **Rescinded (3/22/2021)**~~

~~Remove Conditional Note D. 4. and replace it with "The Petitioner commits to constructing an 8-foot planting strip, and 8-foot sidewalk on Central Avenue per Chapter 19." **Rescinded (3/22/2021)**~~

- ~~Add a site plan note specifying dedication and fee simple conveyance of all rights-of-way to the City before the site's first building certificate of occupancy is issued. CDOT requests rights-of-way set at 2' behind back of sidewalk where feasible.~~

## Advisory Information

The following are requirements of the developer that must be satisfied prior to driveway permit approval. These requirements shall be reflected on the rezoning plan, as appropriate.

- The setback for this district is measured from the back of the existing or future curbline as determined by CDOT and Planning during the permitting process.

## **Rezoning Transportation Analysis**

**Petition Number: Zoning Petition #2021-011**

*General Location Identifier: Tax ID 10304127*

2. CDOT has the authority to regulate/approve all private street/driveway and public street connections to the right-of-way of a street under the regulatory jurisdiction of the City of Charlotte, per the City of Charlotte's Driveway Regulations.
3. Adequate sight triangles must be reserved at the existing/proposed street entrance(s). Two 35' x 35' sight triangles (and two 10' x 70' sight triangles on NCDOT-maintained streets) are required for the entrance(s) to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs shall not interfere with sight distance at the entrance(s) and shall be identified on the site plan.
4. The proposed driveway connection(s) to public streets will require a driveway permit(s) to be submitted to CDOT (and NCDOT on NCDOT-maintained streets) for review and approval. The exact driveway location(s) and type/width of the driveway(s) will be determined by CDOT during the driveway permit process. The locations of the driveway(s) shown on the site plan are subject to change in order to align with driveway(s) on the opposite side of the street and comply with City Driveway Regulations and the City Tree Ordinance.
5. All proposed commercial driveway connections to a future public street will require a driveway permit submitted to CDOT for review and approval.
6. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.
7. A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City-maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to construction/installation. Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements.
8. To attain a street and pedestrian lighting recommendation, the petitioner should coordinate with Anthony Mendez, CDOT. Please visit the following link:  
<https://charlottenc.gov/Transportation/Programs/Pages/StreetLighting.aspx>