

Rezoning Transportation Analysis
Petition Number: Insert Zoning Petition #2021-219
General Location Identifier: 12521103

From: Brandon Brezeale, PE
Brandon.Brezeale@charlottenc.gov
704-432-5561

Reviewer: Walta Blackmon, PE
Walta.Brumskine@charlottenc.gov
704-432-1556

Revision Log:

Date	Description
01/21/2022	First Review (WB)

General Review Information

The petition is located adjacent to Kenilworth Avenue, a City-maintained major thoroughfare, East Morehead Street, a State-maintained major thoroughfare, and Harding Place, a City-maintained Local Road. The site is within the South Corridor inside Route 4 and within the limits of the Midtown/Cherry Area Plan. This site was previously rezoned in 2008 (2008-137; O-2 to MUDD-O) then in 2013, (RZP-2013-092; site plan amendment).

Active Projects Near the Site:
o N/A

CDOT's review of this rezoning petition is intended to provide consistency with council adopted policies, plans, standards and guidelines including, but not limited to, the [Transportation Action Plan \(TAP\)](#), [Vision Zero](#), [Urban Street Design Guidelines \(USDG\)](#), [Center, Corridor and Wedges](#), [Charlotte BIKES](#), [Traffic Impact Study Guidelines](#) and [Charlotte WALKS](#). With a commitment to design complete streets, this review is to ensure that the City's transportation network supports current and future land uses and includes streets that provide safe and comfortable mobility for motorists, pedestrians, bicyclists, and transit users.

This document is primarily for communication to Planning Department staff as part of the overall City staff analysis of the rezoning petition and includes an overall summary of the case from a transportation perspective, information on trip generation, and resolved or outstanding site plan concerns. Additional advisory information about the driveway permit process is provided for information only.

Based on our review of the petition, we offer the following information for your consideration.

Transportation Summary

The petition is located adjacent to Kenilworth Avenue, a City-maintained major thoroughfare, East Morehead Street, a State-maintained major thoroughfare, and Harding Place, a City-maintained Local Road. A Traffic Impact Study (TIS) is not needed for this site. The Site Plan commits to accommodating pedestrian and bicycle facilities on Kenilworth Avenue, in accordance with the Charlotte WALKS and Charlotte BIKES Plans. Site plan revisions are needed to include clarifying conditional notes. Further details are listed below.

Rezoning Transportation Analysis
Petition Number: Insert Zoning Petition #2021-219
General Location Identifier: 12521103

Trip Generation

Scenario	Land Use	Intensity	Trip Generation (vehicle trips/day)	Source
Existing Use	Multifamily Commercial (combination of retail office, restaurant, etc.)	380 Units *SF is variable based on use	9,135	<i>Tax Record</i>
Entitlement with Current Zoning	Multifamily Commercial (combination of retail office, restaurant, etc.)	380 Units *SF is variable based on use	9,135	<i>2013-092</i>
Proposed Zoning	Multifamily Commercial (combination of retail office, restaurant, etc.)	388 Units *SF is variable based on use	9,180	<i>Site Plan: 09-03-21</i>

*25,000 SF commercial uses. However, square footage capped at 15,000 SF if drive-through is incorporated. Retail cannot exceed 15,000 SF. 25,000 SF of grocery store shall be allowed.

Provide comments to the specified comments below.

Outstanding Issues

~~Strikethrough~~ = Resolved

1. **Curbline:** The proposed zoning district has a setback measured from back of the existing or proposed future curbline.
 - a. **Morehead Street:** The future location of curb and gutter measures at 36-feet from the centerline to the back of curb to accommodate buffered bike lanes; however, no curb relocation is being required with this petition and the existing curb and gutter may remain at its current location.
 - b. **Kenilworth Avenue:** The existing curb and gutter is in its future location.
 - c. **Harding Place:** The existing curb and gutter is in its future location.

Label and dimension the curb and gutter from the centerline for each road on the site plan.

2. **Traffic Study:**
 A Traffic Impact Study (TIS) is not necessary for the complete review of this petition due to the site generating less than 2,500 daily trips. If during the permitting process the site generates more than 2,500 daily trips, then a traffic study will be required.
3. Add a site plan note specifying that all transportation improvements will be approved and constructed before the site's first building certificate of occupancy is issued as needed. The petitioner may phase transportation improvements if said improvements and phasing are explicitly described in site plan notes.
4. Add conditional note "All public roadway improvements will be subject to the standards and criteria of CDOT and NCDOT, as applicable, to the roadway improvements within their respective road system authority. It is understood that such improvements may be undertaken by the Petitioner on its own or in conjunction with other development or roadway projects taking place within the broad Central Mecklenburg area, by way of a private/public partnership effort or other public sector project support."

Rezoning Transportation Analysis
Petition Number: Insert Zoning Petition #2021-219
General Location Identifier: 12521103

Advisory Information

The following are requirements of the developer that must be satisfied prior to driveway permit approval. These requirements shall be reflected on the rezoning plan, as appropriate.

1. The setback for this district is measured from the back of the existing or future curbline as determined by CDOT and Planning during the permitting process.
2. CDOT has the authority to regulate/approve all private street/driveway and public street connections to the right-of-way of a street under the regulatory jurisdiction of the City of Charlotte, per the City of Charlotte's Driveway Regulations.
3. Adequate sight triangles must be reserved at the existing/proposed street entrance(s). Two 50' x 50' sight triangles (and two 10' x 70' sight triangles on NCDOT-maintained streets) are required for the entrance(s) to meet requirements. All proposed trees, berms, walls, fences, and/or identification signs shall not interfere with sight distance at the entrance(s) and shall be identified on the site plan.
4. The proposed driveway connection(s) to public streets will require a driveway permit(s) to be submitted to CDOT (and NCDOT on NCDOT-maintained streets) for review and approval. The exact driveway location(s) and type/width of the driveway(s) will be determined by CDOT during the driveway permit process. The locations of the driveway(s) shown on the site plan are subject to change in order to align with driveway(s) on the opposite side of the street and comply with City Driveway Regulations and the City Tree Ordinance.
5. All proposed commercial driveway connections to a future public street will require a driveway permit submitted to CDOT for review and approval.
6. Any fence or wall constructed along or adjacent to any sidewalk or street right-of-way requires a certificate issued by CDOT.
7. A Right-of-Way Encroachment Agreement is required for the installation of any non-standard item(s) (irrigation systems, decorative concrete pavement, brick pavers, etc.) within a proposed/existing City-maintained street right-of-way by a private individual, group, business, or homeowner's/business association. An encroachment agreement must be approved by CDOT prior to construction/installation. Contact CDOT for additional information concerning cost, submittal, and liability insurance coverage requirements.
8. The petitioner needs to complete and submit the [Right of way Abandonment Petition form](#) to CDOT for review. The decision of this rezoning petition does not correlate with the decision of the possible abandonment, as this decision is issued within the separate Right of Way Abandonment process that is controlled by North Carolina General Statutes.
9. To attain a street and pedestrian lighting recommendation, the petitioner should coordinate with Anthony Mendez, CDOT. Please visit the following link:
<https://charlottenc.gov/Transportation/Programs/Pages/StreetLighting.aspx>