



## Rezoning Petition Review – Charlotte Tree Ordinance

**Subject:** Urban Forestry Rezoning Petition Review Summary  
**To:** Charlotte Planning, Design & Development  
**From:** Tim Porter, Chief Urban Forester  
[Timothy.Porter@Charlottenc.gov](mailto:Timothy.Porter@Charlottenc.gov)  
 704-622-4829  
**Rezoning Petition:** 2021-090

Date	Description/Status
9/23/2021	UF 2 <sup>nd</sup> review, Tim Porter
8/26/2021	UF 1 <sup>st</sup> review, Tim Porter

### **Standard Requirements**

- Include the following note: *"The site will comply with the Charlotte Tree Ordinance"*

#### City Tree Preservation Requirements – Sec. 21-61

- All existing street trees in public street right-of-way (City or State-maintained) are required to be preserved per the Charlotte Tree Ordinance and the following Tree Ordinance Guidelines:
  1. City Trees & Protected Vegetation
  2. City Tree Mitigation Policy

#### Tree Survey & Protection Plan Requirements – Sec. 21-91; 21-92

- A tree survey shall be submitted identifying all trees of eight-inch (8) dbh or greater and all planted trees of (2) two-inch caliper or greater and six feet in height that grow partially or wholly within public street right-of-way.

#### Tree Save Preservation Requirements – Sec. 21-93 - 96

- Conditional rezoning petition submittals shall provide notation referencing how tree save requirements will be met by the site and depict potential tree save areas.

#### Tree Planting Requirements – Sec. 21-96

- Perimeter tree planting is required along all public roads per the Charlotte Tree Ordinance.
  - o Small-mature trees are required in locations with overhead distribution lines
- Internal tree planting is required to meet surface parking and impervious coverage requirements including for townhome projects with driveway parking.

### **Outstanding Requirement Issues**

~~Strike through~~ = Resolved

- Remove all reference planting area dimensions for internal trees. Adjustments to site design and/or planting area dimensions may be required at time of permitting
- You are required to submit a tree survey for this petition depicting existing trees in public street right-of-way. A tree survey shall be submitted identifying all trees of eight-inch (8) dbh or greater and all planted trees of (2) two-inch caliper or greater and six feet in height that grow partially or wholly within public street right-of-way.
- ~~Final tree save area requirement to be determined at time of permitting. Remove specific acreage references.~~
- ~~Change notes referencing "City Arborist Office" to "Urban Forestry"~~



## Additional Information

