



Subject: Rezoning Petition Review

To: Charlotte Planning, Design & Development

From: Doug Lozner

Date of Review: June 24, 2022

Rezoning Petition #: 22-018

Existing Zoning: R-3

Proposed Zoning: MX-2

Location of Property: Approximately 72.20 acres located south of Johnston Oehler Rd, east of Prosperity Church Rd and west of Mallard Creek Rd.

Site Plan Submitted: Yes

Recommendations

Concerning Storm Water: City of Charlotte GIS data indicates a 100-ft Undisturbed PCSO buffer across the site. Please show and label *Potential 100-ft Undisturbed PCSO Buffer* on the site plan. Any increase of impervious area within such buffers may not be allowed and is not approved with the rezoning process. Stream Delineation Reports are subject to review and approval by Charlotte Storm Water Services. Please include the following note under Environmental Features: *“Development within any SWIM/PCSO Buffer shall be coordinated with and subject to approval by Charlotte-Mecklenburg Storm Water Services and mitigated if required by City ordinance. Petitioner acknowledges intermittent/perennial stream delineation reports are subject to review and approval upon submission of development plans for permitting and are not approved with rezoning decisions.”*